

Addendum #1
IFB08132019
Interior Signage
McHenry County College

This Addendum is in response to the inquiries from potential bidders. This Addendum constitutes changes to the specifications as sent out in the original IFB and other pertinent information shared with all vendors. All changes and information listed on this Addendum should be considered as the official modifications to the specifications and should be included in your proposal with these in mind.

Please acknowledge your receipt of this addendum by attaching a signed copy of the addendum with your proposal response.

Received and acknowledged by: _____

-
1. Is the digitally printed vinyl wall covering (part of B1.1) by others? The acrylic parts are not an issue.
Yes the vinyl wall covering is to be provided by the fabricator as part of the complete B1.1 sign.
 2. Can we flatbed print the graphics on the acrylic panel (part of B1.1) instead of printing onto vinyl and applying the vinyl to the acrylic?
The graphics can be flat bed printed, there are some locations where there is vinyl wall covering that needs to be applied to glass or a textured wall surface.
 3. What is the condition of the ceilings?
Primarily the ceiling conditions are drop ceiling grid system. There may be a few drywall ceiling mounting conditions, but these are limited.